

GOVERNMENT OF THE DISTRICT OF COLUMBIA
DEPARTMENT OF GENERAL SERVICES

RENOVATION OF NEW OFFICE SPACE FOR THE
DEPARTMENT OF SMALL AND LOCAL BUSINESS DEVELOPMENT
AT ONE JUDICIARY SQUARE

AND

RENOVATION OF NEW OFFICE SPACES FOR THE
CRIMINAL JUSTICE COORDINATING COUNCIL

SOLICITATION NO. DCAM-13-CS-0168

Addendum No. 4
Issued: July 8, 2013

This Addendum No. 4 is issued and hereby published on the DGS website on July 8, 2013. Except as modified hereby, the Invitation for Bids ("IFB") remains unmodified.

Item #1

Response to bidder questions for the DSLBD Project.

1. Question - The print shows existing voice and data drops. In the design are we adding to those that show on the print to total 132 dual drop locations or do we disregard them.

Response – Correct. In the initial solicitation package the furniture layout did not have all of the locations for the structured voice and data cabling outlets within the furniture.

2. Question - Are we providing the racks in the closets or using existing?

Response - No, DCNET will provide the communications racks within the OJS building LAN closets.

3. Question - The jacket color of the cables are white for voice, gray for data, and then blue for cable at the wall plate, is this for the patch cable?

Response - Use CAT6 plenum rated "blue" for voice and CAT 6 plenum rated "gray" for data and CAT 6 plenum rated "orange" for wireless. At the wall jack, use blue keystones for voice and orange keystones for the data. Also, use a black modular furniture jack and follow suit with the cabling color schema for the systems furniture as you would for the wall.

Item #2

Response to bidder questions for the CJCC Project.

1. Question - Is the contractor required to supply kitchen equipment (Refrigerator, Microwave, etc.)?

Response - No. See clarification in Equipment Schedule on sheet A3.01.

2. Question - Please clarify if Security access is required for doors (card readers, etc.)

Response - Yes. See sheet A3.01. The two (2) entry doors refer to Note 4 which provides the detail.

4. Question - Detail 8, Drawing 11.30 CJCC shows a sliding door detail. Where is this door, if required. No specs are provided in the project manual.

Response - This sliding door is at the closet is in front of Office 005. The details for the door are on the door schedule, drawing A12.00.

5. Question - The scope says 64 dual runs, 2 runs for analog services, 2 runs for analog conferencing service, and 4 pulls for wireless, and remaining 60 for digital voice and data services.

A. When you say 2 runs is that 2 cables or 4 cables?

Response - The term dual means two (64 dual runs means 128 single runs/pulls of CAT 6 plenum rated communications cables) therefore 2 runs are two single for analog services.

B. The total out of 64 is 13 for analog but the total runs being held out doesn't add up, is this a miscalculation?

Response - Not sure where you got the calculation of 13 analog lines when there is a total of 4 (four) analog lines 2(two) analog lines for fax and 2 (two) analog line for conference lines.


Item #3

Response to bidder questions for the DSLBD and CJCC Project.

Question - Please clarify that no one contractor will be awarded both jobs.

Response - No one contractor will be awarded both jobs. See Addendum No. 1, Item #6.

- End of Addendum No. 4 -

By: 
JW Lantum
Associate Director/ Contracting Officer

Date: 7/8/13